



Republic of the Philippines
 Department of Agriculture
 Bureau of Fisheries and Aquatic Resources
 BIDS AND AWARDS COMMITTEE OFFICE
 3/F PCA Bldg., Elliptical Road, Diliman, Quezon City, Philippines 1101
 Tel. No.: +02. 332. 4661 website: www.bfar.da.gov.ph e-mail: bfarbac2013sec@gmail.com

SUPPLEMENTAL BID BULLETIN 01
 December 7, 2020

SUBJECT: Bid Reference No: 2020-46
REHABILITATION, UPGRADE AND IMPROVEMENT OF THE MACHINERIES, REFRIGERATION SYSTEM AND EQUIPMENT OF THE KOREA-PHILIPPINES-SEAFOOD PROCESSING COMPLEX AT THE BFAR-NIFTDC

This Supplemental Bid Bulletin No. 01 is issued to all participating bidders to clarify, amend and/or modify certain provisions and requirements set forth under the above-entitled procurement project:

Invitation to Bid

FROM/ Bidder's Inquiry	TO/ BFAR Response
Rehabilitation, Upgrade and Improvement of the Machineries, Refriegration System and Equipment of the Korea-Philippines- Seafood Processing Complex at the BFAR-NIFTDC	Rehabilitation, Upgrade and Improvement of the Machineries, Refrigeration System and Equipment of the Korea-Philippines- Seafood Processing Complex at the BFAR-NIFTDC

Technical Specifications

FROM/ Bidder's Inquiry	TO/ BFAR Response
A. REPAIR AND REHABILITATION OF CHILLER ROOM REFRIGERATION SYSTEM with following Technical Specification: DEFROST Heater: 2-1.3Kw Body, 1-1.5Kw Drain Pan, 2-0.4Kw Fan Guide Front	A. REPAIR AND REHABILITATION OF CHILLER ROOM REFRIGERATION SYSTEM with following Technical Specification: DEFROST Heater: 2 units 1.3Kw Body 1 unit 1.5Kw Drain Pan 2 units 0.4Kw Fan Guide Front
E. REPAIR AND REHABILITATION OF PREPARING ROOM REFRIGERATION SYSTEM DEFROST Heater: 2-1.3Kw Body, 1-1.5Kw Drain Pan, 2-0.4Kw Fan Guide Front	E. REPAIR AND REHABILITATION OF PREPARING ROOM REFRIGERATION SYSTEM DEFROST Heater: 2 units 1.3Kw Body 1 unit 1.5Kw Drain Pan 2 units 0.4Kw Fan Guide Front
G. REPAIR AND REHABILITATION OF COLD STORAGE ROOM REFRIGERATION SYSTEM	G. REPAIR AND REHABILITATION OF COLD STORAGE ROOM REFRIGERATION SYSTEM

DEFROST Heater: 2-1.3Kw Body, 1-1.5Kw Drain Pan, 2-0.4Kw Fan Guide Front	DEFROST Heater: 2 units 1.5Kw Body, 1 unit 1.8Kw Drain Pan, 2 units 0.5Kw Fan Guide Front
I. REPAIR AND REHABILITATION OF DIGITAL METAL DETECTOR Control Panel: Digital LCD Panel, Soft Touch Controller-	I. REPAIR AND REHABILITATION OF DIGITAL METAL DETECTOR Control Panel: Digital LCD Panel, Soft Touch Controller- Finedetect (Korea) or similar specifications

Work Order

FROM/ Bidder's Inquiry	TO/ BFAR Response
Chiller Room Refrigeration System	Chiller Room Refrigeration System
LIST OF MATERIALS, PARTS AND COMPONENTS FOR REPAIR OF CHILLER:	LIST OF MATERIALS, PARTS AND COMPONENTS FOR REPAIR OF CHILLER:
Cooper tube and fittings (same size of existing)	Cooper copper tube and fittings (same size of existing)
FOR REPLACEMENT	FOR REPLACEMENT
Temperature indicator controller with sensor (DOTECH digital temp controller)	Temperature indicator controller with sensor (DOTECH digital temp controller or any brand with same specifications)
Marine grade paint	Applicable to other items
Liquid Receiver Tank	Marine grade paint (color: gray, matte finish)
Oil Separator (DHO-22.2)	Liquid Receiver Tank (model: DHRS-050)
Accumulator (DHA-050)	Oil Separator (model: DHO-22.2)
	Accumulator (model: DHA-050)

Bidders are requested conduct site inspection and attach Certificate of Site inspection in bidding documents.

Contact person: Mr. Jose Gamboa III- 09177895302

FINANCIAL COMPONENT ENVELOPE

FROM/ Bidder's Inquiry	TO/ BFAR Response
All Bid proposals must observe the following: <ul style="list-style-type: none"> • DOLE Circular No. 150-16 • DOLE Wage Order No. NCR-22 	All Bid proposals must observe the following: <ul style="list-style-type: none"> • DOLE Circular No. 150-16 • DOLE Wage Order No. NCR-22 <p>DELETE</p>

* Submission of bidding documents:

In the event that the electronic copy cannot be submitted, opened or is corrupted, the BAC will proceed with the opening of the submitted original hard copy.

****nothing follows****

All other portions of the Bidding Documents affected by these amendments shall be made to conform the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (6th Edition, July 2020) are deemed integrated in terms and conditions for this project.

For further inquiries, please coordinate/call the Bids and Awards Committee Secretariat at Tel. No. 8332-4661 or bac.eps@bfar.da.gov.ph.

Please be guided accordingly.

ORIGINAL SIGNED

ATTY. DEMOSTHENES R. ESCOTO

Chairman, Bids and Awards Committee